



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: www.nrclabs.com

September 16, 2020

Bret Marshall  
Talent, City of  
P.O. Box 445  
Talent, OR 97540  
TEL: (541) 535-3828  
FAX: (541) 535-5451

RE: Talent Recovery

Order No.: 20090534

Dear Bret Marshall:

Neilson Research Corporation received 7 sample(s) on 9/15/2020 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,  
Neilson Research Corporation

Tamra Schmedemann  
Senior Project Manager  
245 S Grape St  
Medford, OR 97501



Original



Neilson Research Corporation  
245 S Grape St  
Medford, OR 97501  
TEL: (541) 770-5678 FAX: (541) 770-2901  
Website: [www.nrclabs.com](http://www.nrclabs.com)

## Case Narrative

WO#: 20090534  
Date: 9/16/2020

---

**CLIENT:** Talent, City of  
**Project:** Talent Recovery

---

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

---

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 20090534  
 Date Reported: 9/16/2020

**CLIENT:** Talent, City of  
**Lab ID:** 20090534-01A  
**Client Sample ID** PW Shop  
**Project:** Talent Recovery  
**Sample Location:** PW Shop  
**Sample Address:**

**Collection Date:** 9/15/2020 11:08:00 AM  
**Received Date:** 9/15/2020 1:00:00 PM  
**Matrix:** DRINKING WATER  
**PWS #:** 41-00857  
**Source ID:** DIST-A  
**Sample Collector:** BRET MARSHALL

Analyses	Code	Method	NELAP		Qual		RL Units	Date		Analyst
			Status	Result	DF	MCL		Analyzed		
Benzene	2990	E524.2	A	ND	1	0.000500 mg/L	0.00500	09/15/20	17:05	CSB
Ethylbenzene	2992	E524.2	A	ND	1	0.000500 mg/L	0.700	09/15/20	17:05	CSB
Toluene	2991	E524.2	A	ND	1	0.000500 mg/L	1.00	09/15/20	17:05	CSB
Xylenes, Total	2955	E524.2	A	ND	1	0.000500 mg/L	10.0	09/15/20	17:05	CSB
Surr: Dibromofluoromethane		E524.2	A	93.2	1	80 - 120 %Rec		09/15/20	17:05	CSB
Surr: Toluene-d8		E524.2		96.2	1	80 - 120 %Rec		09/15/20	17:05	CSB
Surr: 4-Bromofluorobenzene		E524.2		97.8	1	80 - 120 %Rec		09/15/20	17:05	CSB

**QUALIFIERS**

CI Sample container temperature is out of limit as specified at testcode  
 MI Recovery outside control limits due to Matrix Interference  
 PL Permit Limit  
 H Holding times for preparation or analysis exceeded  
 ND Not Detected at the Reporting Limit

Original

**NELAP**

NELAP A Accredited. ORELAP 100016, OR-028



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 20090534  
 Date Reported: 9/16/2020

**CLIENT:** Talent, City of  
**Lab ID:** 20090534-02A  
**Client Sample ID** 110 E Main  
**Project:** Talent Recovery  
**Sample Location:** 110 E Main  
**Sample Address:**

**Collection Date:** 9/15/2020 11:44:00 AM  
**Received Date:** 9/15/2020 1:00:00 PM  
**Matrix:** DRINKING WATER  
**PWS #:** 41-00857  
**Source ID:** DIST-A  
**Sample Collector:** BRET MARSHALL

Analyses	Code	Method	NELAP		Qual		RL Units	Date		Analyst
			Status	Result	DF	MCL		Analyzed		
Benzene	2990	E524.2	A	ND	1	0.000500 mg/L	0.00500	09/15/20	17:27	CSB
Ethylbenzene	2992	E524.2	A	ND	1	0.000500 mg/L	0.700	09/15/20	17:27	CSB
Toluene	2991	E524.2	A	ND	1	0.000500 mg/L	1.00	09/15/20	17:27	CSB
Xylenes, Total	2955	E524.2	A	ND	1	0.000500 mg/L	10.0	09/15/20	17:27	CSB
Surr: Dibromofluoromethane		E524.2	A	94.6	1	80 - 120 %Rec		09/15/20	17:27	CSB
Surr: Toluene-d8		E524.2		97.6	1	80 - 120 %Rec		09/15/20	17:27	CSB
Surr: 4-Bromofluorobenzene		E524.2		98.6	1	80 - 120 %Rec		09/15/20	17:27	CSB

**QUALIFIERS**

CI Sample container temperature is out of limit as specified at testcode  
 MI Recovery outside control limits due to Matrix Interference  
 PL Permit Limit  
 H Holding times for preparation or analysis exceeded  
 ND Not Detected at the Reporting Limit

Original

**NELAP**

NELAP A Accredited, ORELAP 100016, OR-028



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 20090534  
 Date Reported: 9/16/2020

**CLIENT:** Talent, City of  
**Lab ID:** 20090534-03A  
**Client Sample ID** 307 Wagner  
**Project:** Talent Recovery  
**Sample Location:** 307 Wagner  
**Sample Address:**

**Collection Date:** 9/15/2020 11:50:00 AM  
**Received Date:** 9/15/2020 1:00:00 PM  
**Matrix:** DRINKING WATER  
**PWS #:** 41-00857  
**Source ID:** DIST-A  
**Sample Collector:** BRET MARSHALL

Analyses	Code	Method	NELAP		Qual		RL Units	Date		Analyst
			Status	Result	DF	MCL		Analyzed		
Benzene	2990	E524.2	A	ND	1	0.000500 mg/L	0.00500	09/15/20 17:51	CSB	
Ethylbenzene	2992	E524.2	A	ND	1	0.000500 mg/L	0.700	09/15/20 17:51	CSB	
Toluene	2991	E524.2	A	ND	1	0.000500 mg/L	1.00	09/15/20 17:51	CSB	
Xylenes, Total	2955	E524.2	A	ND	1	0.000500 mg/L	10.0	09/15/20 17:51	CSB	
Surr: Dibromofluoromethane		E524.2	A	94.2	1	80 - 120 %Rec		09/15/20 17:51	CSB	
Surr: Toluene-d8		E524.2		98.1	1	80 - 120 %Rec		09/15/20 17:51	CSB	
Surr: 4-Bromofluorobenzene		E524.2		98.4	1	80 - 120 %Rec		09/15/20 17:51	CSB	

**QUALIFIERS**

CI Sample container temperature is out of limit as specified at testcode  
 MI Recovery outside control limits due to Matrix Interference  
 PL Permit Limit  
 H Holding times for preparation or analysis exceeded  
 ND Not Detected at the Reporting Limit

Original

**NELAP**

NELAP A Accredited, ORELAP 100016, OR-028



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 20090534  
 Date Reported: 9/16/2020

**CLIENT:** Talent, City of  
**Lab ID:** 20090534-04A  
**Client Sample ID** PD  
**Project:** Talent Recovery  
**Sample Location:** PD  
**Sample Address:**

**Collection Date:** 9/15/2020 12:10:00 PM  
**Received Date:** 9/15/2020 1:00:00 PM  
**Matrix:** DRINKING WATER  
**PWS #:** 41-00857  
**Source ID:** DIST-A  
**Sample Collector:** BRET MARSHALL

Analyses	Code	Method	NELAP		Qual		RL Units	Date		Analyst
			Status	Result	DF	MCL		Analyzed		
Benzene	2990	E524.2	A	ND	1	0.000500 mg/L	0.00500	09/15/20	18:14	CSB
Ethylbenzene	2992	E524.2	A	ND	1	0.000500 mg/L	0.700	09/15/20	18:14	CSB
Toluene	2991	E524.2	A	ND	1	0.000500 mg/L	1.00	09/15/20	18:14	CSB
Xylenes, Total	2955	E524.2	A	ND	1	0.000500 mg/L	10.0	09/15/20	18:14	CSB
Surr: Dibromofluoromethane		E524.2	A	93.1	1	80 - 120 %Rec		09/15/20	18:14	CSB
Surr: Toluene-d8		E524.2		98.4	1	80 - 120 %Rec		09/15/20	18:14	CSB
Surr: 4-Bromofluorobenzene		E524.2		99.6	1	80 - 120 %Rec		09/15/20	18:14	CSB

**QUALIFIERS**

CI Sample container temperature is out of limit as specified at testcode  
 MI Recovery outside control limits due to Matrix Interference  
 PL Permit Limit  
 H Holding times for preparation or analysis exceeded  
 ND Not Detected at the Reporting Limit

Original

**NELAP**

NELAP A Accredited, ORELAP 100016, OR-028



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 20090534  
 Date Reported: 9/16/2020

**CLIENT:** Talent, City of  
**Lab ID:** 20090534-05A  
**Client Sample ID** 1734 Lithia Way  
**Project:** Talent Recovery  
**Sample Location:** 1734 Lithia Way  
**Sample Address:**

**Collection Date:** 9/15/2020 12:20:00 PM  
**Received Date:** 9/15/2020 1:00:00 PM  
**Matrix:** DRINKING WATER  
**PWS #:** 41-00857  
**Source ID:** DIST-A  
**Sample Collector:** BRET MARSHALL

Analyses	Code	Method	NELAP		Qual		RL Units	Date		Analyst
			Status	Result	DF	MCL		Analyzed		
Benzene	2990	E524.2	A	ND	1	0.000500 mg/L	0.00500	09/15/20 18:37	CSB	
Ethylbenzene	2992	E524.2	A	ND	1	0.000500 mg/L	0.700	09/15/20 18:37	CSB	
Toluene	2991	E524.2	A	ND	1	0.000500 mg/L	1.00	09/15/20 18:37	CSB	
Xylenes, Total	2955	E524.2	A	ND	1	0.000500 mg/L	10.0	09/15/20 18:37	CSB	
Surr: Dibromofluoromethane		E524.2	A	94.1	1	80 - 120 %Rec		09/15/20 18:37	CSB	
Surr: Toluene-d8		E524.2		97.5	1	80 - 120 %Rec		09/15/20 18:37	CSB	
Surr: 4-Bromofluorobenzene		E524.2		99.0	1	80 - 120 %Rec		09/15/20 18:37	CSB	

**QUALIFIERS**

CI Sample container temperature is out of limit as specified at testcode  
 MI Recovery outside control limits due to Matrix Interference  
 PL Permit Limit  
 H Holding times for preparation or analysis exceeded  
 ND Not Detected at the Reporting Limit

Original

**NELAP**

NELAP A Accredited. ORELAP 100016, OR-028



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 20090534  
 Date Reported: 9/16/2020

**CLIENT:** Talent, City of  
**Lab ID:** 20090534-06A  
**Client Sample ID** 625 Anderson  
**Project:** Talent Recovery  
**Sample Location:** 625 Anderson  
**Sample Address:**

**Collection Date:** 9/15/2020 12:05:00 PM  
**Received Date:** 9/15/2020 1:00:00 PM  
**Matrix:** DRINKING WATER  
**PWS #:** 41-00857  
**Source ID:** DIST-A  
**Sample Collector:** BRET MARSHALL

Analyses	Code	Method	NELAP		Qual		RL Units	Date		Analyst
			Status	Result	DF	MCL		Analyzed		
Benzene	2990	E524.2	A	ND	1	0.000500 mg/L	0.00500	09/15/20	18:59	CSB
Ethylbenzene	2992	E524.2	A	ND	1	0.000500 mg/L	0.700	09/15/20	18:59	CSB
Toluene	2991	E524.2	A	ND	1	0.000500 mg/L	1.00	09/15/20	18:59	CSB
Xylenes, Total	2955	E524.2	A	ND	1	0.000500 mg/L	10.0	09/15/20	18:59	CSB
Surr: Dibromofluoromethane		E524.2	A	90.6	1	80 - 120 %Rec		09/15/20	18:59	CSB
Surr: Toluene-d8		E524.2		95.3	1	80 - 120 %Rec		09/15/20	18:59	CSB
Surr: 4-Bromofluorobenzene		E524.2		97.7	1	80 - 120 %Rec		09/15/20	18:59	CSB

**QUALIFIERS**

CI Sample container temperature is out of limit as specified at testcode  
 MI Recovery outside control limits due to Matrix Interference  
 PL Permit Limit  
 H Holding times for preparation or analysis exceeded  
 ND Not Detected at the Reporting Limit

Original

**NELAP**

NELAP A Accredited. ORELAP 100016, OR-028





Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# Analytical Report

WO#: 20090534  
 Date Reported: 9/16/2020

**CLIENT:** Talent, City of  
**Lab ID:** 20090534-07A  
**Client Sample ID** 5517 S Pacific Hwy  
**Project:** Talent Recovery  
**Sample Location:** 5517 S Pacific Hwy  
**Sample Address:**

**Collection Date:** 9/15/2020 12:30:00 PM  
**Received Date:** 9/15/2020 1:00:00 PM  
**Matrix:** DRINKING WATER  
**PWS #:** 41-00857  
**Source ID:** DIST-A  
**Sample Collector:** BRET MARSHALL

Analyses	Code	Method	NELAP		Qual		RL Units	Date		Analyst
			Status	Result	DF	MCL		Analyzed		
Benzene	2990	E524.2	A	ND	1	0.000500 mg/L	0.00500	09/15/20	19:22	CSB
Ethylbenzene	2992	E524.2	A	ND	1	0.000500 mg/L	0.700	09/15/20	19:22	CSB
Toluene	2991	E524.2	A	ND	1	0.000500 mg/L	1.00	09/15/20	19:22	CSB
Xylenes, Total	2955	E524.2	A	ND	1	0.000500 mg/L	10.0	09/15/20	19:22	CSB
Surr: Dibromofluoromethane		E524.2	A	94.1	1	80 - 120 %Rec		09/15/20	19:22	CSB
Surr: Toluene-d8		E524.2		99.0	1	80 - 120 %Rec		09/15/20	19:22	CSB
Surr: 4-Bromofluorobenzene		E524.2		100	1	80 - 120 %Rec		09/15/20	19:22	CSB


**QUALIFIERS**

CI Sample container temperature is out of limit as specified at testcode  
 MI Recovery outside control limits due to Matrix Interference  
 PL Permit Limit  
 H Holding times for preparation or analysis exceeded  
 ND Not Detected at the Reporting Limit

Original

**NELAP**

NELAP A Accredited, ORELAP 100016, OR-028



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# QC SUMMARY REPORT

WO#: 20090534  
 16-Sep-20

**Client:** Talent, City of  
**Project:** Talent Recovery

**TestCode:** EPA524.2\_DW

Sample ID: <b>LCS</b>	SampType: <b>LCS</b>	TestCode: <b>EPA524.2_D</b>	Units: <b>mg/L</b>	Prep Date:	RunNo: <b>14513</b>						
Client ID: <b>LCSW</b>	Batch ID: <b>R14513</b>	TestNo: <b>E524.2</b>		Analysis Date: <b>9/15/2020</b>	SeqNo: <b>218389</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Benzene	0.0173	0.000500	0.02000	0	86.5	70	130				
Ethylbenzene	0.0177	0.000500	0.02000	0	88.7	70	130				
Toluene	0.0179	0.000500	0.02000	0	89.4	70	130				
Xylenes, Total	0.0543	0.000500	0.06000	0	90.6	70	130				
Surr: Dibromofluoromethane	0.0367		0.04000		91.8	80	120				
Surr: Toluene-d8	0.0381		0.04000		95.3	80	120				
Surr: 4-Bromofluorobenzene	0.0377		0.04000		94.3	80	120				

Sample ID: <b>MBLK</b>	SampType: <b>MBLK</b>	TestCode: <b>EPA524.2_D</b>	Units: <b>mg/L</b>	Prep Date:	RunNo: <b>14513</b>						
Client ID: <b>PBW</b>	Batch ID: <b>R14513</b>	TestNo: <b>E524.2</b>		Analysis Date: <b>9/15/2020</b>	SeqNo: <b>218390</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Benzene	ND	0.000500									
Ethylbenzene	ND	0.000500									
Toluene	ND	0.000500									
Xylenes, Total	ND	0.000500									
Surr: Dibromofluoromethane	0.0377		0.04000		94.3	80	120				
Surr: Toluene-d8	0.0386		0.04000		96.6	80	120				
Surr: 4-Bromofluorobenzene	0.0388		0.04000		97.1	80	120				

**Qualifiers:** C1 Sample container temperature is out of limit as specified at testcode H Holding times for preparation or analysis exceeded MI Recovery outside control limits due to Matrix In  
 ND Not Detected at the Reporting Limit PL Permit Limit RL Reporting Detection Limit

Original



Neilson Research Corporation  
 245 S Grape St  
 Medford, OR 97501  
 TEL: (541) 770-5678 FAX: (541) 770-2901  
 Website: www.nrclabs.com

# QC SUMMARY REPORT

WO#: 20090534  
 16-Sep-20

**Client:** Talent, City of  
**Project:** Talent Recovery

**TestCode:** EPA524.2\_DW

Sample ID: <b>20090534-07AMS</b>	SampType: <b>MS</b>	TestCode: <b>EPA524.2_D</b>	Units: <b>mg/L</b>	Prep Date:	RunNo: <b>14513</b>						
Client ID: <b>5517 S Pacific Hwy</b>	Batch ID: <b>R14513</b>	TestNo: <b>E524.2</b>		Analysis Date: <b>9/15/2020</b>	SeqNo: <b>218398</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Benzene	0.0177	0.000500	0.02000	0	88.4	70	130				
Ethylbenzene	0.0185	0.000500	0.02000	0	92.4	70	130				
Toluene	0.0184	0.000500	0.02000	0	91.8	70	130				
Xylenes, Total	0.0558	0.000500	0.06000	0	93.0	70	130				
Surr: Dibromofluoromethane	0.0398		0.04000		99.6	80	120				
Surr: Toluene-d8	0.0398		0.04000		99.5	80	120				
Surr: 4-Bromofluorobenzene	0.0400		0.04000		100	80	120				

Sample ID: <b>20090534-07AMSD</b>	SampType: <b>MSD</b>	TestCode: <b>EPA524.2_D</b>	Units: <b>mg/L</b>	Prep Date:	RunNo: <b>14513</b>						
Client ID: <b>5517 S Pacific Hwy</b>	Batch ID: <b>R14513</b>	TestNo: <b>E524.2</b>		Analysis Date: <b>9/15/2020</b>	SeqNo: <b>218399</b>						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Benzene	0.0199	0.000500	0.02000	0	99.3	70	130	0.01768	11.6	20	
Ethylbenzene	0.0207	0.000500	0.02000	0	103	70	130	0.01847	11.3	20	
Toluene	0.0205	0.000500	0.02000	0	103	70	130	0.01837	11.0	20	
Xylenes, Total	0.0631	0.000500	0.06000	0	105	70	130	0.05577	12.4	20	
Surr: Dibromofluoromethane	0.0402		0.04000		100	80	120		0	0	
Surr: Toluene-d8	0.0404		0.04000		101	80	120		0	0	
Surr: 4-Bromofluorobenzene	0.0406		0.04000		102	80	120		0	0	

**Qualifiers:** C1 Sample container temperature is out of limit as specified at testcode H Holding times for preparation or analysis exceeded MI Recovery outside control limits due to Matrix In  
 ND Not Detected at the Reporting Limit PL Permit Limit RL Reporting Detection Limit

Original

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information	Section B Required Project Information	Section C Invoice Information	Section D Rush Status (Subject to Scheduling)
Company: <u>City of Talent</u>	Project Name: <u>Talent Recovery</u>	Attention:	<input type="checkbox"/> Standard: 10 Business Days
Address: <u>200 Suncrest Rd</u>	Project Number:	Company Name:	<input type="checkbox"/> Priority: 5 Business Days (List x 1.50)
<u>Talent, OR. 97540</u>	Report To:	Address:	<input type="checkbox"/> Express: 3 Business Days (List x 1.75)
Email: <u>BMarshall@CityofTalent.org</u>	Copy To:	P.O. #	<input type="checkbox"/> Rush: 2 Business Days (List x 2.00)
Phone: <u>541-535-3828</u> Fax:			<input type="checkbox"/> Rush: 1 Business Day (List x 2.50)
Collected By (Print): <u>Bret Marshall</u>			<input type="checkbox"/> Rush: Same Day (List x 3.00)
Collected By (Sign): <u>Bret Marshall</u>			Authorized <input type="checkbox"/> Yes <input type="checkbox"/> No
Email Report <input checked="" type="checkbox"/> Mail Report <input type="checkbox"/> Fax Report <input type="checkbox"/>			

Section E Sample Information					Analysis Requested										NRC Workorder # (Lab Use Only) <u>20090534</u>						
Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers													Remarks / Field Data	NRC Sample # (Lab Use Only)	(Lab Use Only)	
<u>P.W. Shop</u>			<u>9/15/20</u>	<u>11:08am</u>	<u>BTEX</u>															<u>01</u>	
<u>110 E. Main</u>				<u>11:44am</u>																<u>02</u>	
<u>307 Wagner</u>				<u>11:50am</u>																<u>03</u>	
<u>PD</u>				<u>12:10pm</u>																<u>04</u>	
<u>1734 Lithia</u>				<u>12:20PM</u>																<u>05</u>	
<u>625 Anderson</u>				<u>12:05PM</u>																<u>06</u>	
<u>5517 S. Pac</u>			<u>9/15/20</u>	<u>12:30 PM</u>																<u>07</u>	

\*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F		Sign	Print	Date	Time
Relinquished By:	<u>Bret Marshall</u>			<u>9/15/2020</u>	<u>13:00</u>
Received By:					
Relinquished By:					
Received By:					
Relinquished By:					
Received By Laboratory:	<u>Denise Neal</u>	<u>Denise Neal</u>		<u>9/15/2020</u>	<u>13:00</u>

Section G Lab Use Only	
Temp:	<u>17.7</u>
≤6°C:	<input type="checkbox"/> Yes <input type="checkbox"/> No
Received on Ice:	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Number of Bottles Received:	<u>35</u>
pH Checked:	<u>NA</u>
COC Seals Intact:	<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA
Field Blank Included:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Received Via	<input type="checkbox"/> UPS <input type="checkbox"/> FedEx <input type="checkbox"/> Other <input checked="" type="checkbox"/> Hand

Payment: <input checked="" type="checkbox"/> Invoice <input type="checkbox"/> Cash <input type="checkbox"/> VISA, M/C <input type="checkbox"/> Check # _____ Amount _____
---